



## **ADDENDUM #1**

### **CITY OF MILPITAS MILPITAS, CALIFORNIA ENGINEERING DIVISION**

### **CONTRACT DOCUMENTS AND SPECIFICATIONS FOR**

### **2014 Soundwall Renovation Jacklin Road @ Hillview Drive & Del Rio Court**

### **PROJECT NO. 4267**

Date: May 5, 2015

To: Plan Holders - Prospective Bidders of the subject project

From: Steve Erickson, CIP Manager

---

Attached is Addendum #1 for the subject project. This addendum forms a part of the Contract Documents and modifies the Bid Documents as noted below. Acknowledgement of receipt of this addendum in the space provided in the Proposal is required. Failure to acknowledge an addendum may subject the bidder to disqualification.

---

At 2 p.m. on May 13, 2015, all bidders will submit their bids as set forth in bid documents and as amended by the following:

**ADDENDUM #1**

Refer to the Specifications:

**1. A-01 Notice Inviting Bids:**

**CHANGE** the Contractor's License requirements specified in the 1st sentence of the fourth paragraph from Class A or C 33 **TO Class B**.

**2. The following are the answers to questions asked at the May 1, 2015 pre-bid meeting:**

*a. Are the original plans for the Del Rio Court soundwall available? **Yes, these can be obtained from the City upon request.***

*b. For the Del Rio Court wall, rather than drilling and installing new concrete piers, can the original piers be reengineered and improved to allow them to remain in place with a new wall being attached to the old piers? **It is unlikely the existing piers can be enhanced sufficiently to meet the current building and seismic code.***

*c. Both soundwall work locations have a fair amount of landscape that may require pruning. There appears to be some landscape that can not be pruned and may require removal and replacement. How will this be handled? **Technical Specification Section E-02 specifies the requirement of the contractor to provide for the minor pruning of trees and landscape as required to complete the specified work. However, the removal and replacement of trees and landscape is not intended, and the contractor will need to work around such obstacles. Also note that damage to landscape or property is the contractors responsibility to repair or replace.***

**END OF ADDENDUM #1**

---

This addendum shall be signed by each bidder and kept for their files. Acknowledgement of receipt of this addendum in the space provided in the Proposal is required. Failure to acknowledge an addendum may subject the bidder to disqualification.

I,

---

representing

---

have carefully read this addendum, understand it, acknowledge receipt of this addendum and will comply its terms.

This addendum is issued by  for the City of Milpitas, on 5-1-15