

CITY OF MILPITAS

Building & Safety Department
455 E. Calaveras Blvd.
Milpitas, CA 95035
408-586-3240
www.ci.milpitas.ca.gov



ACCESSIBLE PARKING INSPECTION CHECKLIST

- ❑ Single Parking Stalls – CBC1129B.3
 - Shall be 14 foot wide
 - 5 foot loading and unloading access aisle on the passenger side of the vehicle)
 - 9’0” Min. Width (Dimension to centerline of stripe)
 - 18’0” Min. Depth (Dimension from face of walk or curb)

- ❑ Double Parking Stalls-CBC1129B.3
 - Shall be 23 foot wide (For Accessible Parking Stall)
 - Shall be 26 foot wide (For Van accessible Parking Stall)
 - 9 foot parking area on each side (5 foot loading and unloading access aisle on center for accessible parking stall and 8 foot for van accessible parking stall)
 - 18’0” Min. Depth (Dimension from face of curb or walk)

- ❑ 70 square inch Accessibility Sign –CBC 1129.B.4

- ❑ Typical Pavement Symbol- CBC 1129B.4

- ❑ Wheel Stop-If required

- ❑ Stripes at 36” on center-CBC1129B.3

- ❑ “NO PARKING” in 12” high letters (Min.)-CBC1129B.3

- ❑ Access aisle border painted blue - CBC 1129B.4

- ❑ Additional sign at off-street parking entrance - CBC 1129B.4