

# CITY OF MILPITAS

Building & Safety Department  
455 E. Calaveras Blvd.  
Milpitas, CA 95035  
408-586-3240  
[www.ci.milpitas.ca.gov](http://www.ci.milpitas.ca.gov)



## ACCESSIBLE RAMP INSPECTION CHECKLIST

---

- Top platform- 60” minimum when no door swings into landings
- Top platform- When door swings onto landing- 42” minimum plus door width
- Intermediate level platform- 60” minimum
- Intermediate turning platform (more than 30 degree turn) - 72” minimum
- Bottom landing – 72” minimum and in direction of ramp run
- Landing width – Top landing: 60” min.; Intermediate and Bottom landing: same as ramp run width
- Ramp landing at doorway- 24” minimum exterior and 18” minimum interior beyond the strike edge of a gate or door on the side toward which it swings
- Wheel guide-3” plus minus 1”
- Handrail-Minimum 34” not exceeding 38”
- Handrail extension - 12” minimum beyond the landing or transition between ramp and landing and parallel to the floor
- Guards – required for ramps over 30” high and guards top rail at 42” from top of ramp
- Width – Minimum 36” clear for residential; 48” minimum for commercial
- Ramp slope – 1:12 max.
- Ramp rise – 30” max. in each ramp run