

CITY OF MILPITAS

Building & Safety Department
455 E. Calaveras Blvd.
Milpitas, CA 95035
408-586-3240
www.ci.milpitas.ca.gov



RESIDENTIAL SANITARY SEWER LATERAL INSPECTION CHECKLIST

-
- Cleanout shall be installed per City of Milpitas Standard Drawing No.620
 - Cleanout box shall be Christy G-5 Box
 - G5C Lid and G5GR or approved equal with “C.O.” or “S” marking
 - Cast iron traffic cover required in sidewalk or driveway
 - Plug shall be approved and labeled
 - Riser shall be the same size as sewer lateral
 - Building sewer drainage constructed of approved materials
 - Minimum grade at lateral shall be ¼” per foot (2 percent)
 - Building sewer cleanouts shall be extended to grade and comply with CPC Section 707
 - Building sewer shall be tested at its points of connection with the Public Sewer and completely filling the building sewer with water from the lowest to the highest point
 - Where sidewalk is not contiguous with street curb, cleanout should be placed 6” behind street curb