




**City of Milpitas
Building And Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

Policy:	BDP-BLG14
Effective Date:	6/11/13
Proposed by:	BYC
Last Reviewed/ Revised:	5/10/17
Revised by:	BYC

**DEMISING WALL IN
COVERED MALL**

Approved By: Gary King
Acting Chief Building Official


CODE REFERENCES:

2016 CBC Section 708.1 & 708.4

ISSUES:

CBC section 708.1 requires demising walls separating tenant spaces in covered mall buildings to be 1-hr fire-rated partition and CBC sec.708.4, Exception 4, allows the fire-rated partition to terminate at the underside of a ceiling that is not part of a fire-resistance-rated assembly. In an existing covered mall building, when the tenant on one side of the demising wall proposes to remove the ceiling to expose the roof structure or raise the ceiling height, the continuity of the fire-rated partition will be compromised.

POLICY:

When the tenant on one side of the demising wall in covered mall removes the ceiling to expose the roof structure or raises the ceiling height, the 5/8" Type X gypsum board on the tenant's side is required to extend to the new ceiling or to the underside of the roof deck. All joints shall be fire taped. Smoke seal shall be provided at the joint to the roof deck.