



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

Policy:	BDP-BLG26
Effective Date:	5/13/2009
Proposed by:	OC
Last Reviewed/ Revised:	05/11/2017
Revised by:	JAC

**ALLOWABLE LATERAL BEARING
PRESSURE FOR POLE TYPE
FOOTINGS**

Approved By: Gary King
Acting Chief Building Official

1. The maximum allowable foundation pressure, lateral pressure or lateral sliding resistance values for supporting soils near the surface shall not exceed the values specified in 2016 CBC Table 1806.2 for clay soils (class 5 material), unless data to substantiate the use of a higher value is submitted and approved.
2. Isolated poles for uses such as flagpoles, signs and fences that are not adversely affected by a 0.5" horizontal motion at the ground surface due to short-term lateral loads are permitted to be designed using lateral-bearing values equal to two-times the tabular values with 1.33 increase, i.e. 266 psf/ft for clay soils.