



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**Access & Entrance to Electrical Equipment
in Multi-Tenancy Building**

Policy:	BDP-EL01
Effective Date:	1/1/2011
Proposed by:	
Last Reviewed/ Revised:	6/14/17
Revised by:	BK
Approved By: Gary King Acting Chief Building Official	

In conformance with sections 90.4 and 110.26(C) of the 2016 California Electrical Code, the following interpretation is provided:

“In multiple tenancy buildings, the following access and entrance to electrical equipment are acceptable:

1. All required entrances must be located on the exterior of the building, or
2. Interior public corridor leading directly to building exit.

In single tenancy buildings, the required entrances may be a combination exterior/interior”