




**City of Milpitas  
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California  
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 [www.ci.milpitas.ca.gov](http://www.ci.milpitas.ca.gov)

**Multiple tenancy branch circuits  
and disconnects**

<b>Policy:</b>	BDP-EL02
Effective Date:	03/21/1996
Proposed by:	
Last Reviewed/ Revised:	1/28/19
Reviewed/ Revised by:	BYC
Approved By:	Bill Tott Building Official 

**Official Interpretation 2016 CEC Multiple Tenancy Branch  
Circuits and Disconnects**

In conformance with sections 90.4, 230.72 (C) and 240.24 (A) and (B) of the 2016 California Electrical Code, the following interpretation is provided:

- 1) Branch circuits shall not be shared between tenants.**
- 2) Where multiple tenancies occur, each tenant shall be provided with dedicated panel with approved disconnecting means and must be accessible to tenants.**