




**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**Water bonding to a grounding
electrode**

Policy:	BDP-EL04
Effective Date:	3/7/2011
Proposed by:	
Last Reviewed/ Revised:	3/2/2018
Revised by:	BK
Approved By: Gary King Acting Chief Building Official 	

Interior metal water piping requires a bonding jumper conductor connection to:

1. The service equipment enclosure. or
2. The grounded conductor at the service. or
3. The grounding electrode conductor where of sufficient size. or
4. **To one or more of the grounding electrodes used.**

If the reinforcing steel rebar in the footing (Ufer) is used, as in item 4 above, then the grounding electrode conductor from the service to the rebar must be of equal or larger than that required for the water bonding jumper.

If a #4 was used from the service to the rebar and a #2/0 was required for the water bond this would not be acceptable.

If the electrode conductor & bonding jumper were both #2/0 this would be acceptable.

The water bonding jumper may not be larger than the grounding electrode conductor in this return path.