



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**Protection of working space clearances
at electrical equipment**

Policy:

BDP-EL07

Effective Date:

1/1/2014

Proposed by:

LS

Last Reviewed/
Revised:

6/14/17

Revised by:

BK

Approved By: Gary King
Acting Chief Building Official

As per 2016 CEC sec.110.26 (B) working space shall not be used for storage and when in a passageway or general open space shall be suitably guarded.

To properly identify guarded area provide label on the equipment stating that minimum clear distance, as identified by 2016 CEC sec.110.26(A), shall be maintained clear and unobstructed. The depth of the working space shall be minimum 36” and the width is 30” or the width of the equipment, whichever is greater.