



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**NEW AND MODIFIED
GAS PIPING SYSTEMS**

Policy:	BDP-PL06
Effective Date:	8/01/2012
Proposed by:	MM
Last Reviewed/ Revised:	
Reviewed/ Revised by:	
Approved By:	Keyvan Irannejad P.E. Chief Building Official



2010 California Plumbing Code. New and modified gas pipe systems shall be required to be pressure-tested in accordance with the 2010 California Plumbing Code. Section 1214.0.

*** Any additional piping exceeding 6' in length connected to an existing system the entire piping system shall be required to pass a pressure test**

Exceptions:

- 1. Where new branches are installed from the point of delivery to new appliance, only the newly installed branches shall be required to be pressure-tested.**
- 2. If new piping is connected to an existing system (maximum 6') piping can be tested with a noncorrosive leak-detecting fluid or approved leak-detecting device.**