



LATERAL

Notes:

1. Cleanout box and lid shall be per Standard Drawing No. 602.
2. Plug shall be vitrified clay or rubber.
3. Customer service connection shall be made under the supervision of the Building department. (If on private property)
4. Riser shall be the same size as sewer lateral.
5. Minimum grade at lateral shall be 1/4" per foot.
- △ 6. Pipe material shall be ABS from main to C.O.. Cleanout should be placed 6" behind street curb or as approved by City Engineer.

NOT TO SCALE

CITY OF MILPITAS, ENGINEERING DIVISION

STANDARD DRAWING

SANITARY SEWER LATERAL - COMM./INDUSTRIAL

NO. 618

REVISION

DATE

△ 1

1991

△ 2

2001

△ 3

2010

△ 3

APPROVED BY:

PUBLIC WORKS DIRECTOR / CITY ENGINEER RCE No. 40283

DATE : 6/15/10

SHEET 1 OF 1