



**LATERAL**

**Notes:**

- 1. Clean out shall be installed as shown hereon. Clean out box shall be Christy G-5 BOX and G5C Lid and G5GR Grade Ring or approved equal with "C.O." or "S" marking. Cast iron traffic cover (Christy G-5 or approved equal) is required in sidewalk & driveway.
- 2. Plug shall be vitrified clay or rubber.
- 3. Customer service connection shall be made under the supervision of the Building department. (If on private property)
- 4. Minimum grade of lateral shall be 1/4" per foot.
- 5. Riser shall be the same size as sewer lateral.
- 6. Pipe material shall be ABS from main to C.O.. Cleanout should be placed 6" behind street curb or as approved by City Engineer.

NOT TO SCALE

CITY OF MILPITAS, ENGINEERING DIVISION		STANDARD DRAWING <b>NO. 620</b>
REVISION	DATE	<b>SANITARY SEWER LATERAL - RESIDENTIAL</b>
1	1966	
2	2001	
3	2010	DATE : 6/15/10
APPROVED BY:		SHEET 1 OF 1
PUBLIC WORKS DIRECTOR / CITY ENGINEER RCE No. 40283		