

LATERAL

Notes:

2 1. Clean out shall be installed as shown hereon. Clean out box shall be Christy G-5 BOX and G5C Lid and G5GR Grade Ring or approved equal with "C.O." or "S" marking. Cast iron traffic cover (Christy G-5 or approved equal) is required in sidewalk & driveway.
2. Plug shall be vitrified clay or rubber.
3. Customer service connection shall be made under the supervision of the Building department. (If on private property)
4. Minimum grade of lateral shall be 1/4" per foot.
5. Riser shall be the same size as sewer lateral.
1 6. Where sidewalk is not contiguous with street curb, cleanout should be placed 6" behind street curb.

NOT TO SCALE

CITY OF MILPITAS, ENGINEERING DIVISION				STANDARD DRAWING
REVISION	DATE	DESIGNED: MK	SANITARY SEWER LATERAL (RESIDENTIAL)	NO. 620
1	4/15/05	DRAWN: JH		
2	12/5/05	CHECKED: JH		ORIGINAL DATE: 3/10/66
		2 APPROVED BY: CITY ENGINEER	12/5/05 DATE: 12/5/05	SHEET 1 OF 1